

# Export d'alarmes UPS via SNMP-M2

1. Aller sur l'interface web de la carte SNMP, puis aller dans le **menu alarme**

The screenshot shows the Statron monitoring interface. The top navigation bar includes 'ALARME' and 'STATUT DES SAISIES DE SORTIE'. The main content area is divided into several panels: 'FLUX D'ÉNERGIE' (Energy Flow), 'ALARMES ACTIVES : (1)' (Active Alarms), and 'ENVIRONNEMENT' (Environment). The 'ALARMES ACTIVES' panel shows a single active alarm: '14/04/2023 07:35:54 IPM / ATS-NBK-004 - Communication perdue avec l'agent'. A red arrow points from this section towards the 'ALARME' menu in the top navigation bar.

2. Pour finir, appuyer sur le bouton **Exporter** et un fichier texte sera téléchargé

The screenshot shows the 'Alarms' section of the Statron monitoring interface. The top right corner of this section contains 'Exporter' and 'Effacer' buttons. A red arrow points to the 'Exporter' button. Below the buttons is a list of alarms with columns for status, time, and description. A detailed view of an alarm is shown on the right side of the screen.

#	Code	1200
👁	Etat	Fermé
📍	Gravité	Attention
🕒	Apparu le	15:12:14
🕒	Disparu le	15:15:11